

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 3261-0713:0108

CATEGORY: 3261 -- FOLDING DOOR (FIRE-RATED)

LISTEE: COOKSON2417 S 50TH AVE, Phoenix, AZ 85043
Contact: Traian Dimache (602) 272-4244 Fax (866) 448-6798
Email: tdimache@cooksondoor.com

DESIGN: Fire Kontrol™ Model KFDM50 folding accordion door. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, fire rating and UL label.

APPROVAL: Listed as 1/3 hour, 1/2 hour, 3/4 hour, 1 hour, 1 1/2 hour, and 3 hour fire-rated interior automatic-closing horizontal folding doors. Authority having jurisdiction should be consulted prior to installation. Opening size not to exceed 9 feet high and 11 feet wide.

Doors exceeding the above limits are considered oversize construction and are based upon , and is similar to, the approval product design, but they have not been subject to approval testing due to test facility limitations. Acceptance of these doors is the prerogative of the authority having jurisdiction.

XLf: 3261-0550:0107

01-06-2010 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2010**

Listing Expires **June 30, 2011**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division