

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

Page 1 of 1

**LISTING No.** 3505-0713:0101

**CATEGORY:** 3505 -- SERVICE COUNTER DOOR (FIRE-RATED)

**LISTEE:** COOKSON2417 S 50TH AVE, Phoenix, AZ 85043  
Contact: Traian Dimache (602) 272-4244 Fax (866) 448-6798  
Email: tdimache@cooksondoor.com

**DESIGN:** Fire-rated counter top. Counter top shall be constructed of non-asbestos fire resistant material and covered with 0,050" thick high pressure decorative laminate. Counter top shall be less than 1-5/8" thick and not exceed 96" in opening width and 108" in total length. Minimum width is 6" or the wall thickness plus 4", which ever is greater. Fire rated counter is made of top steel or stainless steel (14 gauge) with maximum overall length of counter top 4 feet and maximum size opening of 3 feet. Refer to listee's data sheet for detailed product description and operational considerations.

Min. Width (face of wall mounted): 6" or wall thickness plus 4", which ever is greater.

Min. Width (between jam mounted): 6" or wall thickness, whichever is greater.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name and Warnock Hersey label.

**APPROVAL:** Listed as a 1½-hour fire-rated counter top, manufactured by Timberline and tested by WHI Test #495-PSV-0621-0632 or cold rolled or stainless steel (14 gauge) tested by WHI Test#495-PUS-0645.

**NOTE:** Formerly 3510-0713:101

\*Rev. 08-17-2006



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**  
*Fire Engineering Division*

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 7300-0713:0107

Page 1 of 1

**CATEGORY:** 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

**LISTEE:** COOKSON2417 S 50TH AVE, Phoenix, AZ 85043  
Contact: Traian Dimache (602) 272-4244 Fax (866) 448-6798  
Email: tdimache@cooksondoor.com

**DESIGN:** Models Firefly III, Firefly III Plus, Firefly III Plus with Voiceboard , Test A Fire III, and Test A Fire III with Voiceboard releasing devices. All units are intended to be used in conjunction with a temperature fusible link system to release a maximum 40 lbs. door load. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Firefly III = 24 VDC  
Firefly III Plus = 120 VAC, 24 VAC, 24VDC  
Firefly III Plus with Voiceboard = 120 VAC, 24 VAC, 24 VDC  
Test A Fire III = 120 VAC  
Test A Fire III with Voiceboard = 120 VAC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as releasing devices. For indoor use only. Authority having jurisdiction shall be consulted prior to installation.

**XLf:** 7300-1609:0100

11-15-06 KV



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

**Date Issued:** July 01, 2011

**Listing Expires** June 30, 2012

**Authorized By:** FRANCIS MATEO, Program Coordinator  
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 3505-0713:0104 Page 1 of 1

**CATEGORY:** 3505 – SERVICE COUNTER DOOR (FIRE-RATED)

**LISTEE:** COOKSON2417 S 50TH AVE, Phoenix, AZ 85043  
Contact: Traian Dimache (602) 272-4244 Fax (866) 448-6798  
Email: tdimache@cooksondoor.com

**DESIGN:** Vertical rolling steel service counter door. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:**

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, UL or Warnock Hersey label.

**APPROVAL:** Listed as ¾-hour or 1-hour fire-rated service counter fire doors.

**NOTE:**

Rev 8/06



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

*Listing Expires* **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**  
*Fire Engineering Division*

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 3261-0713:0108

Page 1 of 1

**CATEGORY:** 3261 – FOLDING DOOR (FIRE-RATED)

**LISTEE:** COOKSON2417 S 50TH AVE, Phoenix, AZ 85043  
Contact: Traian Dimache (602) 272-4244 Fax (866) 448-6798  
Email: [tdimache@cooksondoor.com](mailto:tdimache@cooksondoor.com)

**DESIGN:** Fire Kontrol™ Model KFDM50 folding accordion door. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, fire rating and UL label.

**APPROVAL:** Listed as 1/3 hour, 1/2 hour, 3/4 hour, 1 hour, 1 1/2 hour, and 3 hour fire-rated interior automatic-closing horizontal folding doors. Authority having jurisdiction should be consulted prior to installation. Opening size not to exceed 9 feet high and 11 feet wide.

Doors exceeding the above limits are considered oversize construction and are based upon , and is similar to, the approval product design, but they have not been subject to approval testing due to test facility limitations. Acceptance of these doors is the prerogative of the authority having jurisdiction.

**XLFF:** 3261-0550:0107

01-06-2010 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

**Date Issued:** July 01, 2011

*Listing Expires* June 30, 2012

**Authorized By:** FRANCIS MATEO, Program Coordinator  
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 3515-0713:0103  
**CATEGORY:** 3515 – ROLLING STEEL DOOR (FIRE-RATED)

Page 1 of 1

**LISTEE:** COOKSON2417 S 50TH AVE, Phoenix, AZ 85043  
Contact: Traian Dimache (602) 272-4244 Fax (866) 448-6798  
Email: tdimache@cooksondoor.com

**DESIGN:** 22 gauge galvanized or stainless steel slats, bottom bar, wall guides, hoods, barrel assembly automatic release device, governor and counter balance mechanism. Doors may be manual or provided with motor drive assembly which does not interfere with the manual or automatic (fusible link) closing of the door. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:**

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** UL, FM or Warnock Hersey label.

**APPROVAL:** Listed as 3-hour, 1-hour or 3/4-hour fire-rated doors for use in concrete and masonry walls. Rolling steel fire doors maximum size of openings:

WH Label	8'W x 10'H	Maximum 80 sq. ft.
UL, FM Label	13'6"W x 13'6"H	Maximum 152 sq. ft.

For doors exceeding 13'6" in any dimension and 152 sq. ft in area are considered oversize doors and are not cover under this listing. The design of these doors is based upon, and is similar to, the approval product design but they have not been subject to approval testing due to test facility limitations. Acceptance of these doors is the prerogative of the authority having jurisdiction.

**NOTE:**

\*Rev. 08-17-2006



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

**Date Issued:** **July 01, 2011**

**Listing Expires** **June 30, 2012**

**Authorized By:** **FRANCIS MATEO, Program Coordinator**  
**Fire Engineering Division**