

Pursuant to Local Law 76, 1968 Section 27-131 (b) Effective December 6, 1968, the following is a list of materials and equipment which has been tentatively acceptable in accordance with the reports of the Material and Equipment Acceptance Division.

The right to protest this action to the Department of Buildings as specified in Section 27-131 (b) may be exercised within a period of 20 days from the date of this publication.

Complete MEA reports on file at 60 Hudson Street, New York, New York 10013.

Rudolph J. Rinaldi, R.A., Commissioner

MEA 116-90-M

Report of Material and Equipment Acceptance Division

Manufacturer - The Cookson Company, 2417 South 50th Ave., Phoenix, AZ 85043.

Product - Rolling fire door assembly, 3-hour fire protection rating.

Pertinent Code Sections - 27-329, 27-342.

Prescribed test - RS 5-6 (ASTM E152).

Laboratory - Warnock Hersey International, Inc.

Test Report - No.495-0401, dated March 28, 1983.

Description - FD-10 Series rolling steel counter fire door assembly designed for the protection of openings in fire protection rated wall assemblies. Designed for an opening 8'8" wide by 10' high. The door comprises No.22 gauge galvanized steel slats interconnected to form a curtain. The bottom bar consist of two 11-gauge steel angles bolted together to form a "T" section. The guides for the curtain is made from 11-gauge rolled steel angles bolted together and is attached to the gypsum wallboard assembly.

Recommendation - That the above described door, which shall be operated by an approved fusible link or other New York City approved automatic closing mechanism, be accepted as providing 1-1/2 hours fire protection rating when installed in accordance with Reference Standard RS 5-8 (NFPA 80) for Class B openings, on condition that the certificates or labels accompanying all shipments shall be provided by the testing service which shall be regularly engaged by the manufacturer to make periodic inspections and/or tests of the doors in the course of their manufacture. All shipments and deliveries of such materials shall, in addition, be accompanied by a metal tag certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Original Publication MAY 10 1991

Final Acceptance MAY 16 1991

Examined by *Peang*